



Smoke Detector and Carbon Monoxide Self Certification

Permit Number		Date:
Project Address		
Owner Name		Phone:
Project Description		

I, the undersigned, hereby certify that I am the owner, occupant or authorized agent of the above referenced property. I further certify that smoke alarms and carbon monoxide alarms are present and functional in all the following locations. (Retrofitted smoke detectors may be battery operated.)

Notes: All boxes below must be checked.

Smoke Alarms and Carbon Monoxide Alarm: On the ceiling or wall *outside* of each separate sleeping area in the immediate vicinity of bedrooms or in each hallway outside of the rooms.

Smoke Alarms: *In each room* used for sleeping purposes.

Smoke Alarm and Carbon Monoxide Alarm: *In each story*, including any habitable basement. (Note: In dwellings or dwelling units with split levels and without an intervening door between the adjacent levels, a smoke alarm and carbon monoxide detector installed on the upper level shall suffice for the adjacent lower level provided that the lower is less than one full story below the upper level.)

Name

Signature

California Residential Code (CRC) Section R314.1, CRC R315.2 state in part that existing dwellings be "...retrofitted with smoke detectors and carbon monoxide detectors when a building permit is issued for, worked on or in a building that is valued at \$1,000 or more." CRC Section R314.3, CRC R315.3 defines required locations as indicated above.

NOTE: This Certification is only used when normal access to the interior of the dwelling by the City of Ojai Building inspector is not achieved during the course of project construction. It is normally used for projects such as re-roofing, re-siding, patio covers, swimming pools and the like.